

ADDENDUM NO 01

CITY OF FAIRHOPE

To

REQUEST FOR QUOTATIONS RFQ NO. 008-10

THREE PHASE PAD MOUNT TRANSFORMERS

For

Electric Department

The bid documents for this Bid shall be amended, revised and changed in the following particulars:

In response to questions from potential participants in the RFQ:

Question 1: "On page 3 under specifications, section 2 under the features subtitle you are asking for 85 degree C rise. Is this correct?"

Answer: No. 65 degrees C is the correct number.

Responders are to sign and include signed Addendum No.1 with submitted quotation documents.

Acknowledged:

Company

By

Daniel P. Ames
Purchasing Manager
City of Fairhope

Posted: 05-05-2010