

# ADDENDUM NO 02

FOR

CITY OF FAIRHOPE  
BID NO. 017-09  
Emergency Repairs to Well No. 1  
for  
Water Department

The bid documents for this bid shall be amended, revised and changed in the following particulars:

Addendum to be as follows:

The following questions have been submitted by a potential bidder:

1. *'Certificate of insurance and all contract information will be completed after determining award of contract. Is this correct?'*

Answer: This is an Emergency Bid. Our objective is to open the bids, compile and submit a bid tabulation and recommendation to City Council, have City Council award the bid, hand the contracts to the awarded vendor who will sign all sets and include the correctly filled out certificate of insurance, have the Mayor immediately execute the contract, and give the awarded vendor his contract set and a Notice to Proceed, all on the same day. The certificate of insurance must list the City of Fairhope as additionally insured.

2. *'Are you planning to use the existing 50HP Motor?'*

Answer: Yes

3. *'Can we furnish stainless steel impellers instead of bronze?'*

Answer: Yes

4. *'Do you want new airline installed during installation of the pump assembly?'*

Answer: Yes, stainless steel airlines.

5. *'My understanding no bid bond or security is needed at this time. Is this correct?'*

Answer: That is correct, as stated in the bid documents.

Bidders are to sign and include signed Addendum No.1 with submitted bid documents.

Acknowledged:

---

Company

---

By

Daniel P. Ames  
Purchasing Manager  
City of Fairhope

Posted: 04-29-09

end of addendum no. 2